

REQUIRED BUILDING SIGNAGE CHECKLIST



& IBC/IFC/NFPA CODE REFERENCE GUIDE

This checklist includes the most common interior signs required by IBC, IFC, and NFPA safety codes. This is just a guide and not all signage will be applicable for all situations. Additional signage may be required by your local fire codes. If you need assistance determining if the signage is required, please contact your local fire inspector.

✓	Example	Sign Type	Location	Code Reference
		Maximum Occupancy Load	Assembly Occupancy Rooms	2021 IBC Ch. 10, Section 1004.8
		In Case of Fire (or) In Fire Emergency Sign	Elevator Call Stations	2021 IBC Ch. 30, Section 3002.3 2021 IFC Ch. 6, Section 604.4
		Overhead Exit Sign	Exit Egress Doors	2021 IBC Ch. 10, Section 1013.1; Section 1013.5
		Tactile Exit Sign	Exit Egress Doors	2021 IBC Ch. 10, Section 1013.4
		Delayed Emergency Egress Doors	Exit Egress Doors	2021 IBC Ch. 10, Section 1010.2.13.1
		Low-Level Photoluminescent Exit Sign	Exit Egress Doors	2021 IFC Ch. 10, Section 1013.2; Section 1025.2.6.1
		Fire Door Do Not Block (or) Fire Door Keep Closed	Fire-Rated Doors	2021 IFC Ch. 7, Section 705.2.2
		Photoluminescent No Exit Sign	Non-Exit Doors (that could be confused for Exit Doors)	2021 NFPA 101, Section 7.10.8.3

REQUIRED BUILDING SIGNAGE CHECKLIST

& IBC/IFC/NFPA CODE REFERENCE GUIDE

✓	Example	Sign Type	Location	Code Reference
		Stairway Identification Sign	Interior Stairwells	2021 IFC Ch. 10, Section 1023.9
		Tactile Floor Level Sign	Interior Stairwells	2021 IFC Ch. 10, Section 1023.11
		Area of Refuge (or) Exterior Area for Assisted Rescue	Refuge Area Doors	2021 IBC Ch. 10, Section 1009.9; Ch. 11, Section 1112.1
		Photoluminescent Area of Refuge (or) Exterior Area for Assisted Rescue	Refuge Area Doors	2021 IBC Ch. 10, Section 1009.9
		Area of Refuge Instructions	Refuge Areas	2021 IBC Ch. 10, Section 1009.11
		Two-Way Communication System Instructions	Refuge Areas	2021 IBC Ch. 10, Section 1009.6.5; Section 1009.8.2
		Handicap Accessible Directional	Various Public Locations (Such as Refuge Area Doors, Inaccessible Exits, and Elevator Landings)	2021 IBC Ch. 10, Section 1009.10; Ch. 11, Section 1112.3

*Every situation is different. Contact your sales rep or customer service if you have any questions concerning the signs you need.